Monitor Equipment | Monitor Discharge Devices | EKM-I-AX Electrically Operated Remote Controlled Monitor I (Intermediate) Series | ATEX Area | Standard & EFW Configuration



•	Intermediate version electrical monitor, with additional electronic
	features

- Movement by two electrical motors (horizontal and vertical axis)
- Manual + automatic operation. Configured to perform a sweep oscillation between two horizontal extremes
- Standard version or EFW version for installations requiring a - 90 ° downward discharge
- Refer to technical documentation for full list of features, discharge devices and control panels

SPECIFICATIONS							
Related Documents	RFQ / order checklist Technical data page (pending)						
Approvals / Certfications							
Material (Body)	Stainless Steel AISI 316						
Material (Flange)	Stainless Steel AISI 316						
Finish	Flame Red RAL3000 (Epoxy)						
Working pressure	12 bar (max)						
Flow rate	3" Body - 4000 l/min @ 7 bar 4" Body - 8000 l/min @ 7 bar						
Connection Type	ANSI or PN16						
Electrical Motor	3 Phase 400VAC 0.18kW						
Installation Area	ATEX area						
Discharge devices	Manual or electrically adjustable nozzle, foam or water branch pipe						
Vertical range	Standard: -47 ° to +85 ° EFW: -90 ° to +45 °						
Horizontal range	Standard: -170 ° to +170 ° EFW: -90 ° to +90 °						
Options	B Series (Basic) A Series (Advanced)						

Body	Flange	Part Number		Flores	Part Number	
		Standard	EFW	Flange	Standard	EFW
3"	3" ANSI	EKM-S-3X3A-I-AX	EKM-W-3X3A-I-AX	3" PN16	EKM-S-3X3P-I-AX	EKM-W-3X3P-I-AX
3	4" ANSI	EKM-S-3X4A-I-AX	EKM-W-3X4A-I-AX	4" PN16	EKM-S-3X4P-I-AX	EKM-W-3X4P-I-AX
4"	4" ANSI	EKM-S-4X4A-I-AX	EKM-W-4X4A-I-AX	4" PN16	EKM-S-4X4P-I-AX	EKM-W-4X4P-I-AX
4	6" ANSI	EKM-S-4X6A-I-AX	EKM-W-4X6A-I-AX	6" PN16	EKM-S-4X6P-I-AX	EKM-W-4X6P-I-AX

Note: This document contains basic product information only. Information, photos and drawings are not contractually binding. In all cases, the manufacturer's full technical documentation (see "Related Documents" above) remains the reference document. Note that certificates, test reports and approvals may be published in the OEM name. The contents of this publication are subject to modifications without notice. All rights reserved.

